

FIRE HOSE REEL ASSET REGISTER 2020

SITE:	Sample
SITE CONTACT:	Joe Bloggs
CONTACT DETAILS:	999
FIRE REGISTER PRESENT	YES

LEGEND

S	SERVICED
Flow LPM	Flow Rate Litres Per Minute
SP BAR	Static Pressure in BAR
DP BAR	Dynamic Pressure in BAR
Instructions	Operating Instructions Present
ID SIGN =	IDENTIFICATION SIGN
Size	Width Of Hose
I	INSPECTED



<u>FIREPOINT NO.</u>	<u>LOCATION</u>	<u>REEL NO.</u>	<u>REEL TYPE</u>	<u>SIZE</u>	<u>ACTION</u>	<u>FLOW LPM</u>	<u>SP BAR</u>	<u>DP BAR</u>	<u>INSTRUCTIONS</u>	<u>COMPLIANT TO I.S.671-3</u>	<u>REQUIREMENTS TO BRING INSTALLATION TO IS:671-3</u>
1	Opposite Office	1	Auto	19mm	S	48	6	4	YES	YES	NONE
2	Paystation Level -1	2	Auto	19mm	S	48	6	4.1	YES	YES	NONE
3	Riser 9	3	Auto	19mm	S	50	5.5	3.5	YES	YES	NONE
4	Zone B -1	4	Auto	19mm	S	48	6	4	YES	YES	NONE
5	Riser 6	5	Auto	19mm	S	48	6	4.4	YES	YES	NONE
6	Level -1A @ Ramp	6	Auto	19mm	S	48	6	4	YES	YES	NONE
7	TV Amplifier Room	7	Auto	19mm	S	48	6.2	4.2	YES	YES	NONE
8	Zone A -1	8	Auto	19mm	S	48	6	4	YES	YES	NONE
9	Beside Wheelchair Return Bay	9	Auto	19mm	S	48	6	4	YES	YES	NONE
10	Riser 10 -2	10	Auto	19mm	S	48	6,6	4.4	YES	YES	NONE
11	Opposite Carpark Store -2	11	Auto	19mm	S	48	5.8	4	YES	YES	NONE
12	Riser 8 -2	12	Auto	19mm	S	48	6	4.2	YES	YES	NONE
13	Paystation Level -2	13	Auto	19mm	S	48	6	4	YES	YES	NONE
14	Riser 6 -2	14	Auto	19mm	S	48	6.1	4.1	YES	YES	NONE
15	Ramp @ -2C	15	Auto	19mm	I	N/A	N/A	N/A	YES	YES	NONE
16	Level-2C Disabled Bays	16	Auto	19mm	S	48	6	4	YES	YES	NONE
17	Beside Wheelchair Return Bay	17	Auto	19mm	S	48	6.6	4.5	YES	YES	NONE
18	Level -2C	18	Auto	19mm	S	48	6	4.1	YES	YES	NONE